



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1842/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 January 2022

Wah Hung Fire Prevention Equipment Co., Limited
G/F, No. 129 Tai Nan Street,
Prince Edward, Kowloon,
Hong Kong

(Attn.: Mr WONG Tsz Tai)

Dear Sir,

**Approval of “WAH HUNG” Pressure Reducing Valve
(General Acceptance No. C20220065)**

Your letters dated 20 December 2021 and 7 January 2022 refer.

Having considered the test report ref. BC-SUMMARY-2021-199 issued on 14 December 2021 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Wah Nan Fire Fighting Equipment Co Ltd

Country of Origin: the Mainland of China

Brand: Wah Hung

Details of Fitting: Copper alloy pressure reducing valve

Model: WH009

Size: 25mm

Body Markings:  PN16 DN25 2:1 ←

Expiry Date: 7 December 2026

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only