

Test Report
Testing of Plastic Hosereel Shut-off Nozzle
(In-house method)

Date of issue : 22 May 2019

Page 1 of 1 page(s)

Castco LRN : NW0190520-002

Details as supplied by customer

Customer : Wah Hung Fire Prevention Equipment Co., Limited
Address : G/F., No. 75 Bedford Road, Tai Kok Tsui, Kowloon, Hong Kong
Job title : - -
Sample description : Plastic Lever Operated Type of Nozzle
Nominal size : 6mm x 19mm
Manufacturer : Wah Nan Fire Fighting Equipment Co., Ltd.
Brand name : WAH HUNG

Customer's ref. no. : - -

Contract no. : - -

Body marking : 

Item no. : WH018

Origin : China

Specification : HKHA FWP7.1.100.7

Sample submitted by : Wah Hung Fire Prevention Equipment Co., Limited

Laboratory test results

Date of sample received : 20 May 2019

Date of test : 21 May 2019

Specimen no.	NW0190520-002
Apply pressure (bar)	8.5
Total cycle	500
Observation	No damage and leakage was observed

Remark(s) :

1. Test results relate only to the specimen tested.

Checked by :


FU HO MAN
Assistant Technical Manager

Certified by :


LIU KA WAI
Technical Manager

End of Report